



TERMINALS

FULLY INSULATED MALE & FEMALE DISCONNECTS

ITEM #	AWG	SIZE SPEC	MATERIAL	QTY/PACK	PACKS/CASE	COLOR
TFDIN-R25-B	22-16	0.25	Nylon	1,000	10	Red
TFDIN-B25-B	16-14	0.25	Nylon	1,000	10	Red
TFDIN-Y25-B	12-10	0.25	Nylon	500	10	Blue
T13757 / TMDIN-R25 TFDIN-R25	22-16	0.25	Nylon	5 (M) 5 (F)	120	Red
T13734 / TMDIN-B25 TFDIN-B25	16-14	0.25	Nylon	5 (M) 5 (F)	120	Blue
T13753 / TMDIN-Y25 TFDIN-Y25	12-10	0.25	Nylon	5 (M) 5 (F)	120	Yellow

Installation Instructions

- 1) Strip wire insulation 1/4"
 - 2) Insert stripped wire into terminal
 - 3) Crimp tightly using crimping tool
- Stranded copper wire only

Nylon Insulation

600V
105°C

UL Listed

**premium.
industrial.
products.**